

0065



Coastal
The Energy People

007/605 #7

RECEIVED

JUL 29 1993

**DIVISION OF
OIL GAS & MINING**

July 29, 1993

Mr. Don Ostler, Director
Division of Water Quality
Department of Environmental Quality
State of Utah
Salt Lake City, Utah 84114-4870

Dear Mr. Ostler:

RE: NPDES PERMIT UT-0023540

In accordance with conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken July 8, 1993, which had a TDS concentration of 1145 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report was received on July 29, 1993.

Sincerely,

Keith W. Welch

Keith W. Welch
Environmental Coordinator

KWW/gb/425

xc: Division of Oil, Gas & Mining ✓
Ken Payne
Keith Zobell
Michael Reed, EPA
Craig Hilton

Utah Fuel Company

Utah Fuel Company is a subsidiary of Coastal Energy Services, Inc. All rights reserved. 1993